

Williams Visit Report

School: Turner Elementary

Visit Date: September 28, 2007

Facility Notes:

Mechanical Systems

HVAC—A11 Workroom has a leak from the HVAC

Interior Surfaces

Peeling wallpaper in D4

A, B, C & D Wings all have stained ceiling tiles

Windows

D6 has a cracked window glass

Fire Safety

2 fire extinguishers need mounting in Conference Room B

Electrical

Cord needs cover in D5

P4 & P5 have exposed low voltage wiring

Restrooms

Rm. A2 & A4 have broken paper towel dispensers

Rm. A2 is missing soap

All 4 restrooms each have one flushometer broken

Boys' Restroom in Building A has a missing spigot

Playground

Tree stumps are buckling cement causing a trip hazard