

Williams Visit Report

School: Fair Oaks Elementary

Visit Date: September 5, 2007

Facility Notes: Paperwork confirms insufficiencies from Fall 2006 Williams Visit have been resolved.

1. Interior Surfaces:
 - a. In the Cafeteria there is a hole in the wall by the water fountain.
2. Hazardous Materials:
 - a. Peeling paint in the Cafeteria by the entrance
 - b. Peeling paint on the benches in the Kindergarten wing.
3. Drinking Fountains/sinks:
 - a. The faucet in Rm. 9 has a slow drip.
4. Restrooms:
 - a. In the Boys RR by the Office there are cracked tiles by a urinal and the sink next to the stall doesn't work.
5. Overall:
 - a. The condition of the school facility was rated as Good.