

Williams Visit Report

School: Meadow Home

Visit Date: September 19, 2007

Facility Notes:

1. Interior Surfaces
 - a. Rm. 4 Boys RR – loose tile
 - b. Rm. 1 – Formica flooring peeling
 - c. Multi-purpose room floor needs repair
2. Structural Damage
 - a. Rm. 19 – cracked sidewalk, **this was reported in last years visit and has yet to be resolved.**
3. Fire Safety
 - a. Rm. 1 – needs fire extinguisher
 - b. Computer Room & Library have crowded access to doors including a table in Computer room.
4. Electrical
 - a. Lights out in Rooms: 4, Boys RR, Girls RR, near Rm. 36, and Library
 - b. Check electrical box in Rm. 5
5. Drinking fountains
 - a. Rm. 24 – poor flow
6. Restrooms
 - a. All restrooms need soap
7. Playground/School Grounds
 - a. K Playground has rises in cement, possible tree roots, posing a trip hazard
8. Overall Cleanliness: GOOD