

Williams Visit Report

School: Foothill Elementary

Visit Date: September 12, 2007

Facility Notes:

1. Mech. Systems
 - a. No air conditioning in Kitchen or MPR
2. Windows/Doors/Gates/Fences (in & out)
 - a. C5—Girls RR door doesn't open easily
3. Interior Surfaces
 - a. Missing ceiling tiles – E5, G2
4. Fire Safety
 - a. K1—Ladder to roof blocked
 - b. K1 & K2—Shared storage areas very cluttered
5. Electrical
 - a. Loose/missing light fixture covers – K1, K2, A1, A2, B5, D4
 - b. B5—Cords exposed under phone
 - c. C5—Exterior light box is loose
 - d. K1—Cable TV outlet missing cover
 - e. Mall Area—Light broken
 - f. MPR—Broken, uncovered thermostat
6. Pest/vermin Infestation
 - a. Ants—K1, Kitchen
 - b. Dead bird in pigeon spikes in mall coverings
7. Drinking fountains
 - a. A1—Water faucet loose, drinking fountain leaks
 - b. A & B pods—Drinking fountains outside are not operational
 - c. A2—Water fountain not working
 - d. B2—Long neck water faucet broken
 - e. B5—Long neck water faucet leaking
 - f. Outside C5—Drinking fountain not working
8. Restrooms
 - a. Boys RR near B2—No sign, No water
 - b. Girls RR near D4—No paper towels
 - c. "E" pod—Toilets leak

Williams Visit Report

Foothill Elementary Facility Notes (cont):

9. Roofs
 - a. Near D1—Roof drain uncapped

10. Playground/School Grounds
 - a. Teacher & VP complained that the new swings make a load clicking noise. The team heard the noise and feel it seems fine, but it should still be checked.
 - b. Box in Mall walkway dangerous