

# Williams Visit Report

**School:** Parkside Elementary

**Visit Date:** August 29, 2007

## **Facility Notes:**

Drinking Fountains: Problems with drinking fountains and sinks not working were reported in the Cafeteria, the Office, the Library, the 1<sup>st</sup> & 2<sup>nd</sup> Wing (only ½ of fountains working) and Rms. 6 & 17. In one corridor a fountain has a missing part but a work order was provided.

Restrooms: in the upper playground boys' RR a toilet is loose from the wall. It needs to be tightened and re-caulked. The Girl's RR also has a stall that needs to be re-caulked. In the Library the Boy's & Girl's RR's have fan guards that need to be put back on, loose tiles and a light that doesn't work in the Girl's RR. Reported in the 1<sup>st</sup> & 2<sup>nd</sup> Wing RR were loose tiles and a loose sink.

Windows/Doors: Rms. 2, 3 and 8 have cracked windows that have been taped up. In Rm. 2 there are sharp edges on the window frame. A work order has been put in for Rm. 8.

There is also a problem with the parking lot stage door in the Cafeteria.

Roof: Problems on the grounds and roof, at the Kinder Wing, with a rain gutter that is falling and a fence that needs to be strapped.

Electrical: Electrical hazards were seen at an electrical outlet in Rm. 14 and with an extension cord to the Psychology Office.