

# Williams Visit Report

**School:** Stoneman Elementary

**Visit Date:** August 30, 2007

This was a Facilities Only visit.

## **Facility Notes:**

Windows/doors/gates/fences: the cafeteria there is a missing door under the stage; the library has glass broken in the back door; the P.E. storage room has a broken vent in the door; Rm. 307 has a hole in the wall above the door; Rm. 316 has a problem with a broken door closure; the Staff RR has a broken door handle. In the foyer a window is falling out therefore, you are unable to open the door.

Interior Surfaces: Wall/floor/ceiling tiles that were either broke, cracked chipped or stained were seen in Rms. 147, 149, 316, 219 and the Boy's RR. in Rm. 307. Rm. 307 has a hole in the wall above the door.

Electrical: Broken/cracked diffusers were seen in the Cafeteria and outside the Library. A circuit in Rm. 219 is overloaded. The air in the Cafeteria is also too loud. Outside light at Rm. 317 is loose.

Drinking Fountains: The water fountains have no/low water pressure in the Cafeteria and Rm. 219. On the playground outside the 300 Wing – both ends – the water fountain is chipped/leaking.

Hazardous Material: Paint is peeling and stucco is cracked/chipped throughout the school grounds.

Pests/vermin: The girl's RR. in the Cafeteria has ants.

Restrooms: Girls' RR. by Rm. 304 has leaking toilet valves and a faucet that doesn't work.

Structural Damage: Rm. 218 has a plywood ramp - nonskid.

The overall condition of the school facility was rated as good.