

Williams Visit Report

School: Chavez Elementary

Visit Date: September 20, 2007

Facility Notes:

Windows, Doors, Gates, Fences

1. The gates between the portable classrooms are attached only on one side. It is not possible to close and lock these gates. They need to be reattached and locked.
2. One gate between two portable classrooms is rested on its side and propped up against the exterior side wall of the portable building.
3. The double gate along 18th Street is broken at the bottom, with the links twisted, bent and unattached to the frame. The bars on the frame are bent.

Interior surfaces

1. Ceiling tiles are loose, missing or hanging in Rooms 44, 46, 47, 38. Rooms 50 and 51, reported last year, still have loose, and hanging ceiling tiles.
2. There is an exposed nail at the baseboard area in the Girls Restroom #49.
3. The Multi Purpose Room has numerous chips exposing the metal in the wall edges at the entrance area.
4. The filter in a vent in the cafeteria area needs to be changed.

Electrical

1. There are flickering or burned out lights in Rooms 5, 35, 44, 47, 48 and 13, the Library, the Computer Room and the Outside Boys Restroom.
2. There are broken or missing diffusers in Rooms 47 and the Outside Boys' Restroom.

Drinking Fountains

1. The faucet in the sink in Room 2 is loose.
2. One faucet is broken outside of Room 13.
3. The drinking fountains in the alcove by the outside Restrooms (playground) do not work. **This has yet to be resolved from 2005-2006 SARC.**

Restrooms

1. There is a missing or broken soap dispenser and/or no soap in Rooms 4, 48, 49, 47, 12, 13, 16, Playground area Boys and Girls' Restrooms (in other words, all of the restrooms).
2. There are loose toilet seats in Restroom 12 and Restroom 16.
3. The water faucet has extremely low or no pressure in Restrooms 49 and 47 and the outside (playground area) Boys Restroom.
4. The faucet button is broken in Room 4.
5. The hand dryer button is missing in the Boys Restroom #48.
6. The faucet button is missing in the Boys Restroom #47 and the Boys' Restroom #13.
7. There are no paper towels in the outside Boys' Restroom (by the playground).

Overall Cleanliness

1. There is debris strewn around in the alcove outside of the exterior playground area restrooms.
2. The ceiling tile issues and restroom issues remain and need to be resolved.