

Williams Visit Report

School: Grant Elementary

Visit Date: September 18, 2007

Past issues yet to be resolved:

Reported in the Fall 2006 visit and 2007 F.I.T. were four exit doors in the main building that did not lock, needed chains and needed to be replaced. Of the four doors, three double doors still need to be fixed.

There are broken, boarded up windows around the facility. The school has a vandalism problem so many windows are boarded up and have bars on them.

Facility Notes:

1. Windows/Doors/Gates/Fences (in & out)
 - a. Rooms 3, 9 & 11 with windows boarded up for safety,
 - b. Room 41 the emergency right window doesn't open, broken lock
 - c. Room 24 has a broken doorstop outside the door
 - d. Room 12 the bottom of the door is broke away
 - e. The new door to the playground is a tripping hazard.

2. Interior Surfaces
 - a. Room 18 where there was a hole in the wall from an old clock, the wall needs to be closed off and repaired
 - b. Room 20 has loose ceiling tile over the teacher's desk
 - c. Room 21 ceiling tiles need to be replace, attached by wood
 - d. Room 41's mini blinds are bent up on both windows, the rubber baseboard is missing and ceiling tile is out completely
 - e. Room 24 has a hole bashed in the wall
 - f. Entrance to the Main Bldg by the Boiler Room (& Room 10) the floor has exposed sub-floor where doors close – needs replacing
 - g. Multipurpose/Cafeteria/Custodial Room area a doorway piece is missing.

3. Fire Safety
 - a. Room 35 – Emergency Exit was blocked by books
 - b. Library, Room 24, two bookcases are blocking two doors from opening completely.

Williams Visit Report

(Grant Elementary continued)

4. Electrical
 - a. Room 9 – there is a wire dangling and a computer plug is loose
 - b. Room 21 – broken switch plus a plate by the blackboard
 - c. Room 35 – dim lights and needs bulbs in 2 panels,
 - d. Computer Room 24 – has an electrical cord hanging in the middle of the room
 - e. Library, Room 24 a light is out
 - f. The Main Building Entrance by the Boiler Room (& Room 10) has a broken Exit light
 - g. The Multipurpose Cafeteria has two lights burned out and a Breaker Box is open.

5. Drinking fountains
 - a. Room 18 the drinking fountain is loose and swivels
 - b. The fountains near Room 14, 20 and on the Playground don't work.

6. Restrooms
 - a. Girls RR by Room 9 – No soap
 - b. Boys RR near the Multipurpose Room – No soap

7. Roofs
 - a. The Multipurpose Room has an outside leak, a water puddle and is soggy.

8. Playground/School Grounds
 - a. A Playground gate is broken
 - b. A broken bench
 - c. The tetherball mounds that aren't being used are hazardous.

9. Overall cleanliness of the school was good other than graffiti located outside Rooms 20, 21 and 30.