

# Williams Visit Report

**School:** Mira Vista Elementary

**Visit Date:** August 22, 2007

## Facility Notes:

1. Mech. Systems
  - a. Wheel chair lifts do not work.
2. Windows/Doors/Gates/Fences (in & out)
  - a. Broken gate between playground and parking lot
3. Structural Damage
  - a. Level 1 & 2 – Steps between levels have poor drainage, there is puddling, down spouts have been closed off.
4. Fire Safety
  - a. Level 1 & 2 - Wheel chair lifts are broken, the boxes are open with the wires hanging out, exposed.
5. Electrical
  - a. Lights around campus are not sufficient. It is very dark at night and some bulbs have burned out, **this was mentioned in the 2005-2006 SARC and has yet to be addressed.**
6. Restrooms
  - a. Level 1 – Girls RR – water was shut off
  - b. Level 1 – 3 – Boys RR – urinals do not work properly, no paper towels
  - c. Level 3 – Boys RR - Flooding
7. Playground/School Grounds
  - a. Water on steps, slipping hazard
  - b. Gate from Playground to Parking lot was left open, this gate is also too short and is not safe.