

# Williams Visit Report

**School:** Lovonya DeJean Middle School

**Visit Date:** September 17, 2007

## Facility Notes:

1. Mechanical Systems
  - a. C-102 - loose gas nozzles
  - b. E-103 - loose faucets
2. Windows/Doors/Gates/Fences (in & out)
  - a. The rear stairs in C-Wing and the Gym have windows needing to be replaced
  - b. Problems with doorstops were seen throughout. **This was stated in 2005-2006 SARC and has yet to be addressed.**
3. Interior Surfaces
  - a. The following areas are in need of paint: The halls outside Rms. B-104, B-203, C-102, and E-106 and inside Rms. B-206, C-103, C-106, and D-102. **This was stated in 2005-2006 SARC and has yet to be addressed.**
  - b. In the stairwell outside B-104 material is coming off of the ceiling
  - c. The Gym also has padding with tears in it
  - d. Broken drawers were seen in Rms. C-103, C-102, C-106, and C-203
  - e. C-102 has some stained ceiling tiles
  - f. C-106 has a broke cabinet drawer
  - g. B-204 - hole in the wall
  - h. B-206 has tears in the wallpaper.
4. Hazardous Materials
  - a. A spray bottle in B-102 wasn't marked for hazardous materials.
5. Electrical
  - a. Broken lamps in the following areas: Gym and hallway outside B-203
  - b. Gym - broken exit lights
  - c. Outside B-206 - wires are exposed above the stairs
  - d. Rm. B-204 - 2 missing cover plates
  - e. Café/Multi-use room - electrical plates on the floor are loose and causing a tripping hazard.

# Williams Visit Report

## (DeJean Middle School continued)

6. Drinking fountains
  - a. Problems regarding low water pressure in drinking fountains were noted during the Fall 2006 visitation. These problems have not yet been resolved.
  - b. Drinking fountains were not working in following areas: outside C-108 and in the Library
  - c. Girl's Locker Room - no water pressure
  - d. Outside Gym by the bike racks – fountains are clogged and have low to no water pressure, one fountain was extremely dirty.
  
7. Restrooms
  - a. Girls RR, B-108
    1. 1 loose and leaking toilet
    2. 1 toilet that flushes slowly
  - b. B-Wing, Boys RR –
    1. Valve access panel that's open
    2. Peeling paint
    3. Broken toilet paper dispenser
    4. Graffiti
  - c. Girls Locker RR - no toilet paper
  - d. Boys Locker RR - Seat in the handicapped shower has broken loose from the wall.
  - e. There are no paper towels at the washing sink in the Café/Multi-use room.
  
8. Overall Cleanliness: GOOD