

Williams Visit Report

School: Portola Middle School

Visit Date: August 21, 2007

Facility Notes:

1. Windows/Doors/Gates/Fences (in & out)
 - a. Many curtain rods throughout school are bending and falling down.
2. Interior Surfaces
 - a. Rm. 127 – Plaster and paint.
 - b. Theater – Theater seat is missing it's back.
 - c. Rm. 129 – Stained tiles.
 - d. Rm. 126 – Stained C-Tiles
3. Structural Damage
 - a. Major cracks in concrete throughout school property.
4. Electrical
 - a. Rm. 123 – Diffuser missing
 - b. Lights out in Rooms: 121, 157, 260, library, boys locker room and the gym.
 - c. The EXIT light in the gym is out.
5. Pest/vermin Infestation
 - a. Rat droppings in boy's locker rooms.
6. Drinking fountains
 - a. Café drinking fountain has no water.
7. Restrooms
 - a. Boys RR – Urinal coming of the wall.
 - b. 1st floor boys bathroom – urinal is falling off the wall (*District was to fix 8/22*) and one of the stalls at the bottom is rotting and creating sharp edges Throughout school bathrooms have no soap and no paper towels.
 - c. Boys RR in the Gym – Missing sink
 - d. Girls RR – Sink coming away from wall.
8. Roofs
 - a. Rm. 307 – Apparent leak
 - b. Rm. 204 - Leak
9. Playground/School Grounds
 - a. Graffiti throughout

Williams Visit Report

(Portola Middle School continued)

10. Overall Cleanliness: FAIR

Items that still needed to be addressed from the 2004-05 SARC were the severe cracks in the concrete throughout the school grounds and the lack of soap and supplies in the restrooms.