

Williams Visit Report

School: Oak Grove Middle

Visit Date: 8/28/08

Facility Notes:

1. Windows/Doors/Gates/Fences:
 - a. Window screen damaged in Room E-1 (remains from last year)
2. Interior Surfaces:
 - a. Minor ceiling drywall damage in Room F2
 - b. Loose ceiling tile in Room F5
3. Safety Issues:
 - a. Missing handle on Fire Extinguisher cabinet in Gym
 - b. Cabinet doors loose (office)
4. Structural Damage:
 - a. Multi-Use Room—Exterior column has visible crack where structure is supported- visually questionable- advised staff
5. Electrical:
 - a. Room A8—3 lights burned out
 - b. Room F2—1 light burned out
 - c. Exterior hall wall light (bulb) missing in C Wing
6. Drinking fountains/Sinks:
 - a. C-1 Community—Leak under sink on 3rd cabinet
7. Restrooms:
 - a. Bldg. D—in the Boys' restroom the center toilet has a leaking Spud Gasket
 - a. Bldg. D—Girls' restroom needs overall cleaning, especially around and under toilets
 - b. Multi-Use Room—Leak at flush handle in Girls' bathroom