

Williams Visit Report

School: Grant Elementary

Visit Date: September 10, 2008

Facility Notes:

- 1. Windows/Doors/Gates/Fences (in & out)**
 - a. Door outside Room 12 needs to be replaced (dry rot)
 - b. Fence between rooms 38 & 39 needs repair
 - c. Door latch broken in room 22

- 2. Interior Surfaces:**
 - a. Paint chipping from wall in Boys' restroom by room 28
 - b. Ceiling tile missing & need repair in room 39
 - c. Ceiling tile needs repair in room 41
 - d. Interior siding an issue in room 22
 - e. Boys' restroom by room 9 has chipped paint

- 3. Safety Issues:**
 - a. Secure bookshelf to wall in rooms 22, 39 & 41
 - b. Crates stored without secure lashing in room 2

- 4. Structural Damage:**
 - a. Back wall of Library has dry rot- needs repair
 - b. Floor tile missing in room 39
 - c. Skirt coming off exterior outside room 35
 - d. Rm. 22
 1. Missing floor tile
 2. Dry rot

- 5. Electrical:**
 - d. Several lights out in MPR
 - e. Diffuser for lights in kitchen missing
 - f. Electrical cover missing on 2 outlets in room 22
 - g. Lights out in Rm. 2, 29 (main room and back room), and Boys RR by Rm. 9.
 - h. 2 lights out in boys' restroom by room 9
 - i. Lights out as you enter class in room 2
 - j. Lights out in main room and back room of rm. 29

Williams Visit Report

6. **Drinking fountains/Sinks:**
 - a. Sinks dirty/stained in room 2

7. **Playground/School Grounds:**
 - a. Paint ramp to room 41
 - b. Exterior of room 20 needs painting
 - c. Play structure near Rm. 35 – Remove graffiti

8. **Roofs:**
 - a. Downspouts missing on portable room 22 and room 20

9. **Overall Cleanliness**
 - a. Graffiti on play structure