

# Williams Visit Report

**School: Stege Elementary**

**Visit Date: September 25, 2008**

**Facility Notes:**

- 1. Windows/Doors/Gates/Fences (in & out)**
  - a. Cracked windows above MPR
  
- 2. Interior Surfaces:**
  - a. Cracked floor tiles in MPR, Main Hallway, Rm. R-4
  - b. Paint
    1. MPR where mirror was removed
    2. Primary Boys' restroom near urinal
    3. Primary Girls' restroom sink & toilet areas
  - c. Loose ceiling tiles in room R-10, R-19, R-4
  
- 3. Structural Damage:**
  - a. Dry rot outside room 19
  - b. Ramp outside room 24 need to be repositioned-trip hazard
  
- 4. Electrical:**
  - a. Lights out in MPR
  
- 10. Restrooms:**
  - a. Upper level Boys' restroom has a plugged urinal
  - b. RR that need soap dispensers: Primary Boys, Primary Girls, and Upper level Girls.
  
- 11. Overall Cleanliness – GOOD**