

Williams Visit Report

School: Verde Elementary

Visit Date: September 17, 2008

Facility Notes:

- 1. Windows/Doors/Gates/Fences (in & out)**
 - a. Windows broken in Cafeteria above door and back of stage.
- 2. Interior Surfaces:**
 - a. Plaster missing from walls in Boys' restroom-Main Hallway, Boys RR-C Wing and Girls' RR-C Wing.
 - b. No paper towel dispensers in Rm. C-12 and Rm. D-16
- 3. Fire Safety:**
 - a. In D-16 fire extinguisher needs to be mounted
- 4. Electrical:**
 - a. **Extreme Deficiency:** In Kitchen the shunt trip panel needs interior cover plate and lock
- 10. Drinking fountains/Sinks:**
 - a. Drinking fountain in Main Hall has no water
 - b. Broken drain pipes in back of B & C Wings- water shut off
 - c. No water in fountain in room C-12
 - d. No water at faucet in room D-16
- 11. Restrooms:**
 - a. Graffiti in Boys' restroom in Main Hall
 - b. No soap in Boys' restroom in B-Wing
 - c. No soap in Boys' restroom in C-Wing
 - d. No soap in Girls' restroom in B-Wing
- 12. Overall Cleanliness – Exemplary**
 - a. While the school is very clean and well maintained many items listed on Report are left over from the 2006-2007 SARC