

Williams Visit Report

School: De Anza High School

Visit Date: September 18, 2008

Facility Notes:

1. Windows/Doors/Gates/Fences (in & out)

- a. Loose window in Room 202
- b. Cracking paint on door in Room 357
- c. Broken window in Kitchen office
- d. Broken window in Cafeteria
- e. West side doors of Cafeteria delaminating
- f. Hanging curtain in Room 258
- g. Issue with curtains in Room 251 (not specified)

2. Interior Surfaces:

- a. Missing ceiling tiles in Main Hall
- b. Graffiti in Rooms 202 & 251
- c. No room number on Room 259
- d. Missing cabinet in room 259
- e. Missing/chipped floor tiles, missing cabinet door in Room 457
- f. Hole in southwest corner of Cafeteria
- g. Chipped floor tiles in Cafeteria
- h. Ceiling tile cracked in Rooms 2, 5 & 7
- k. Missing ceiling tiles in Main Hall South side Girls' restroom
- i. Painting needed throughout Main Hall
- j. Cabinets in Rooms 2, 5, 108, 201, 353 and 355 need to be anchored
- k. Torn wallboard in room 457

3. Safety Issues:

- a. No fire extinguishers in any of the Portables #1-7

4. Electrical:

- a. Lamps out in Main Hall and North side Boys' restroom
- b. Broken diffusers in rooms 251, 253, 259, 252, 257
- c. Electrical receptacle burnt behind teacher's desk in room 252
- d. Lamps out in room 457 and the Cafeteria
- e. Cracked diffuser and leaking ballast in room 353
- f. Diffusers cracked and missing in room 256
- g. Missing diffusers in room 357

Williams Visit Report

Electrical Continued (De Anza High):

- h. Missing diffusers/lamps out in room 207
- i. Broken diffusers in room 258
- j. Cracked diffusers in rooms 355, 257, 401
- k. Missing receptacle plate behind teacher's desk in room 203
- l. Issues with diffusers in rooms 204 & 255 (not specific)

5. Restrooms:

- a. Missing drain cover, attic door open in Main Hall
South side Boys' restroom
- b. Plugged toilets, messy, open attic door in Main Hall
South side Girls' restroom