

# Williams Visit Report

**School: Pinole Middle School**

**Visit Date: 9/15/08**

## **Facility Notes:**

1. Mechanical Systems
  - a. Missing fan vent cover in East side Girls' bathroom
  - b. Missing thermostat cover in Room 47
2. Windows/Doors/Gates/Fences (in & out)
  - a. Window screen missing in Rooms 46 and 47
  - b. Door delaminating in Room 43
  - c. Window cracked in Room 48
  - d. Window sill deteriorating in Room 32
  - e. No window lock in Room 32
  - f. Blind next to heater closet not working properly in Room 20
  - g. Heater closet door binding in Room 20
  - h. Issue with door closer in Room 19
3. Interior Surfaces:
  - a. Cracks in concrete entrances to New/Main Building
  - b. East side Boys' and Girls' bathrooms have missing ceiling tiles
  - c. Flooring cracking in East side Girls' bathroom
  - d. Painting needed in East side Girls' bathroom
  - e. Ceiling tiles torn in Rooms 44 and 47
  - f. Ceiling tiles loose and wall board torn in Room 46
  - g. Floor tile chipped in Room 46
  - h. Wallboard torn with holes in Room 45
  - i. Wallboard torn in Room 43
  - j. Chipped paint by counter next to door in Room 22
  - k. Whiteboard not installed properly in Room 20
4. Safety Issues:
  - a. Cabinet needs anchoring in Room 32
5. Electrical:
  - a. Broken locks on electrical panels in kitchen
  - b. Light Diffuser missing in Room 45
  - c. Lights out in Rooms 32 and 43

# Williams Visit Report

## Facility Notes Continued (Pinole Middle School):

6. Restrooms:
  - a. Stall door closures out of alignment in Boys' and Girls' restrooms in Main Bldg.
  - a. East side Boys' bathroom has broken receptacle cover
  - b. East side Boys' bathroom has no soap
  - c. East side Girls' bathroom has Graffiti
  
7. Playground/School Grounds:
  - a. Asphalt work needed in Play area
  - b. Ramps to portables need non-skid repainting
  
8. Overall Cleanliness
  - a. East side Boys' bathroom is dirty
  - a. Spider webs in Room 46
  - b. Dirty window screen in Room 45
  - c. Heater supply vents dirty in Room 48