

# Williams Visit Report

**School: Peres Elementary**

**Visit Date: September 10, 2010**

## **Facility Notes:**

1. Interior Surfaces
  - a. Room K1 – Metal cabinet not secured, overhead storage issues
  - b. Room 13 – Bookcases not secured
  - c. Library – Loose ceiling tiles
2. Pest/Vermin Infestation
  - a. Room 3 – Ants near door and recycle bin
3. Electrical
  - a. Room 9 – Light outlet cover missing in hallway, work order submitted
4. Restrooms
  - a. Primary Boys Restroom – Sink and urinal leaks, loose toilet seats
  - b. Primary Girls Restroom – Smoke alarm missing, light out
5. Hazardous Materials
  - a. Room 24 – Cleaning supplies in room
  - b. Cleaning supplies under sink in rooms K1 and 13
6. Structural Damage
  - a. Library – Back outside wall has wood rot
  - b. Multi-Purpose Room – Hallway overhang missing vent grate
7. Playgrounds/School Grounds
  - a. Kindergarten Playground – Play structure has a worn rubber step, trip/fall hazard
  - b. Trees near room 14 leaning against building, work order submitted
8. Overall Rating: FAIR