

Williams Visit Report

School: Shannon Elementary

Visit Date: September 27, 2010

Facility Notes:

1. Interior Surfaces
 - a. Excessive clutter needs to be removed in several classrooms
 - b. Lunchroom – Cracked floor tiles
2. Electrical
 - a. Cord management issues in rooms 1, 8, 9
 - b. Missing light covers in rooms 2, 5, 14; work order submitted
 - c. Lunchroom – Broken light cover, cord management issues
3. Restrooms
 - a. Boys Restrooms – Broken screens on outside vents by restroom located near room 1 and 7
 - b. Girls Restrooms – Toilet does not flush and sink does not work in restroom by room 7
4. Playground/School Grounds
 - a. Kindergarten Playground – Graffiti, gate latch not working properly
5. Overall Rating: FAIR