

Williams Visit Report

School: De Anza High School

Visit Date: September 23, 2010

Facility Notes:

1. Mech/HVAC
 - a. Rooms 202, 203, 251, 258, 259 – Heater grill missing
2. Interior Surfaces
 - a. Rooms 107, 108 109, 253, 257, 357 – Ceiling tiles missing or damaged
 - b. Rooms 109, 251, 259, 356 – Bookshelf needs to be secured
 - c. Room 360 – Light cover stained from old leak
 - d. Library – Formica counter face coming off
 - e. Main Halls – Broken lockers
3. Overall Cleanliness
 - a. Room 356 – Bad smell in back of room from unknown cause
4. Electrical
 - a. Room 2 – Light out
 - b. Room 251, Library – Light covers missing
 - c. Rooms 251, 259 – Thermostat cover missing
5. Restrooms
 - a. Boys Restroom North – Lights out
 - b. Boys Restroom South – Light covers missing, rust stains on terrazzo floor
 - c. Girls Restroom South – Toilets 7 and 8 from right leaking, door closer missing, lights out
 - d. Boys Restroom Café – Exposed wiring needs a cover plate, ceiling tiles missing or damaged
 - e. Girls Restroom Café – Faucet leaking
 - f. Boys Locker Room – Towel dispenser broken, graffiti
6. Sinks/Fountains
 - a. Outside Room 353 – Hose bib leaking
 - b. Café – Fountain not working
 - c. Main Halls – South fountain not working
 - d. Outside Café – Fountain not working

Williams Visit Report

7. Fire Safety
 - a. Room 201 – Fire extinguisher mount needs to be attached to wall, replace old fire extinguisher
8. Windows/Doors/Gates/Fences
 - a. Room 352 – Broken window
 - b. Main Halls – Door closure broken
9. Overall Rating: FAIR