

Williams Visit Report

School: Kennedy High School

Visit Date: September 21, 2010

Facility Notes:

1. Mech/HVAC
 - a. Room 124 – File cabinet blocking return on HVAC
 - b. Room 132 – TV blocking HVAC
 - c. Room 200 – HVAC not working

2. Interior Surfaces
 - a. Room 131 – Remove hooks from wall
 - b. Room 211 – Floor tiles missing by door
 - c. Room 212 - Ceiling tiles broken and/or missing
 - d. Room 219 – Cabinet needs to be secured, floor tiles missing
 - e. Kitchen – Holes in floor in serving area, wall damage by back door, back door screens missing, walk-in refrigerator has mold
 - f. Café – Holes in floor by fountain
 - g. Gym – Ceiling tiles missing and/or damaged
 - h. Boys Locker Room – Broken lockers, holes in walls, nails sticking out of display board
 - i. Girls Locker Room - Graffiti

3. Overall Cleanliness
 - a. Room 211 – Overhead storage issues

4. Electrical
 - a. Room 129 – Light covers missing
 - b. Lights out in rooms 131, 209, 210, 211, 214, 219, 403, 406
 - c. Room 209 – Exposed wires from the network cabling
 - d. Room 212 – Larger cover plate needed for call button
 - e. Hallway by Room 213 – Lights out
 - f. Room 219 – Missing cover plate
 - g. Room 403 – Missing clock
 - h. Room 406 – Cover plate missing or broken near door
 - i. Room 407 – Missing outlet cover plate
 - j. Kitchen – Lights out in serving area, conduit sticking out of floor
 - k. Café – Lights out
 - l. Gym – Lights out, exposed wiring by men and women’s staff restroom, cover plate missing

Williams Visit Report

5. Restrooms
 - a. Boys Upstairs by Room 131 – Graffiti scratched in mirror, threshold loose, broken ceramic tile
 - b. Girls Upstairs by Room 131 – Broken ceramic tile
 - c. Boys Downstairs by Room 205 – Broken ceramic tiles, threshold missing

6. Sinks/Fountains
 - a. Room 407 – Sink faucets loose and broken
 - b. Kitchen – Loose faucet
 - c. Near Teachers Room – Fountain broken

7. Fire Safety
 - a. Kitchen – Exit doors of serving area have no panic hardware or door handles only keyed deadbolts
 - b. Café – No fire extinguishers
 - c. Gym – No fire extinguishers

8. Windows/Doors/Gates/Fences
 - a. Room 131 – Door closure broken
 - b. Room 210 – Door closure missing
 - c. Room 406 – Door closure missing
 - d. Café – Exterior doors in need of repair
 - e. Gym – Main doors need repair, broken handle

9. Overall Rating: FAIR