

Williams Visit Report

School: Richmond High School

Visit Date: September 14, 2010

Facility Notes:

1. Mech/HVAC
 - a. Room 656 – Sharp metal on HVAC unit
 - b. Theater – HVAC grill missing left side of stage

2. Interior Surfaces
 - a. Ceiling tiles missing and/or damaged in rooms 307, 309, 556, 557, 652, 655, 661, and café
 - b. Room 306 – Exposed sheetrock
 - c. Room 611 – Burnt material on stove
 - d. Room 557- Hole in wall for future AC
 - e. Bookcase needs anchoring in rooms 310, 337, 339, 372, 374, 555, 557, 661
 - f. Room 555 – Hole in wall for future AC
 - g. Room 507 – Door casing missing
 - h. Boys and Girls Locker – Broken lockers
 - i. Gym – Bleachers broken
 - j. Theater – Carpets dirty
 - k. Kitchen – Concrete needs to be removed, floor repaired
 - l. Computer Room – Wallpaper peeling

3. Overall Cleanliness
 - a. Wing 500 – Graffiti
 - b. Room 374 – Boxes stacked too high
 - c. Room 310 – Boxes stacked throughout

4. Electrical
 - a. Lights out in rooms 303, 304, 307, 308, 309, 339, 340, 341, 363, 371, 372, 374, 430, 433, 438, 555, 557, 559, 606, 607, 611, 634, 650, 652, 655, 656, 659, library, boys locker room, gym
 - b. Room 306 – Outside room wires sticking out of electrical box
 - c. Room 362 – Exposed wires, light switch not working
 - d. Room 611 – Electrical outlet sticking out of floor, tripping hazard
 - e. Room 607 – Light switch cover broken
 - f. Room 557 – Light switch cover broken, light covers missing
 - g. Room 655 – Electrical cover plate missing

Williams Visit Report

- h. Room 656 – Extension cord needs to be removed from surge protector
 - i. Room 661 – Light covers loose, light switch cover missing
 - j. Room 606 – Exposed wires need cover
 - k. Room 340 – Light switch cover broken
 - l. Room 374 – Cord management issues
 - m. Room 310 – Exposed wiring, cord management issues
 - n. Room 555, 556 – Light covers missing
 - o. Room 500 – Electrical boxes on floor do not work, now a tripping hazard
 - p. Library – Humming light fixtures
 - q. Boys Locker – Exposed wiring
 - r. Gym – Light covers missing, no GFI receptor under fountain, exit lights out
 - s. Weight Room – Exposed wires, all lights out or switch not working, exit lights out
 - t. Dance Room – Exit lights out
 - u. Mall & Café – Electrical cover plates broken
 - v. Computer Room – Electrical cover plate missing, extension cords piggybacked on surge protectors
5. Restrooms
- a. Café Girls Restroom – Soap dispenser loose, door knob missing
 - b. Café Boys Restroom – Door knob missing
6. Sinks/Fountains
- a. Room 607 – Faucet knob missing, drinking fountain not working
 - b. Room 606 – No water to sinks
 - c. Room 372 – No water
 - d. Boys Locker Room – No hot water, missing faucet handle
 - e. Mall & Café – Fountain very dirty
 - f. Kitchen – Custodian closet has no water for clean up
7. Hazardous Materials
- a. Chemicals under sink in Room 341, 362, 611, and 652
8. Playground/School Grounds
- a. Grounds – Metal steel plate in asphalt outside weight room

Williams Visit Report

9. Windows/Doors/Gates/Fences
 - a. Door closers broken or missing for rooms 337, 607, 557, 656, 659, 661
 - b. Room 651 – Exterior door deteriorating
 - c. Girls Locker – Broken windows
 - d. Dance Room – Exterior doors broken
 - e. Entrance – Graffiti carved into front windows
 - f. Kitchen – Remove gate

10. Overall Rating: FAIR