

Williams Visit Report

School: Walter T. Helms Middle School

Visit Date: September 8, 2010

Facility Notes:

1. Interior Surfaces
 - a. Dance Room G-125 – Missing and loose base around built in cabinet
2. Fire Safety
 - a. Multi-Use/Stage – Fire extinguisher missing
 - b. Courtyard/Grounds – Lock missing on fire hydrant valve by gym
3. Overall Rating: EXEMPLARY