

Williams Visit Report

School: Lovanya DeJean Middle School

Visit Date: September 17, 2010

Facility Notes:

1. Interior Surfaces
 - a. Room 103 – Base missing
 - b. Room 204 – Peeling wallpaper
 - c. Building B, C, and D Hall – Acoustical ceiling material being scraped off by students in stairwell
 - d. Kitchen – Peeling paint in snack bar area
 - e. Gym – Torn padding on walls
 - f. Dance Room – Hole in wall, ceiling tiles missing or damaged

2. Restrooms
 - a. Girls Locker and Restroom – Hand dryers not working
 - b. Boys Locker and Restroom – Hand dryers not working, shower handles missing
 - c. Boys Restroom E Building – Hole in wall behind door, restroom not in use
 - d. Girls Restroom D Building – Partition broken/missing, toilet loose, restroom not in use
 - e. Boys Restroom C Building – Urinal and toilets loose, excessive water on floor under urinal possibly from a leak
 - f. Girls Restroom B Building – Toilet loose

3. Fire Safety
 - a. Gym Foyer – Exit sign light out

4. Hazardous Materials
 - a. Dance Room – Broken glass in fire extinguisher box

5. Overall Rating: GOOD