

Williams Visit Report

School: Mira Vista Elementary and Middle School

Visit Date: September 24, 2010

Facility Notes:

1. Interior Surfaces
 - a. Room 10 – Tall cabinets and bookcases need to be secured
2. Overall Cleanliness
 - a. Room 7 – Overhead storage area overfull, potential issue if earthquake
 - b. Auditorium/Stage – Not able to get to chair lift for disabled located to the side of the stage due to excessive amount of storage items
3. Electrical
 - a. Room 10 – Lights out
 - b. Room 12 - Lights out
 - c. Disability Chair Lifts – Both lifts not working (wheelchair access by ramp only)
 - d. Auditorium/Stage – Lights out, thermostat cover broken
4. Sinks/Fountains
 - a. Room 2 – Loose faucet
 - b. Room 13 – Low water pressure to fountain
 - c. Room 15 – Fountain not working
5. Playground/School Grounds
 - a. Almost all concrete ramping to classroom doors deteriorating
6. Windows/Doors/Gates/Fences
 - a. Room 23 – Window blinds broken
7. Overall Rating: GOOD