

Williams Visit Report

School: Pinole Middle School

Visit Date: September 20, 2010

Facility Notes:

1. Interior Surfaces
 - a. Room P48 – Back wall panel has broken trim
 - b. Hallways – Hole in wall next to door of Science Lab 4
 - c. Gym – Fire extinguisher box handle broken
2. Overall Cleanliness
 - a. Library – Carpet dirty
3. Electrical
 - a. Room B-20 – Lights out and flickering
 - b. Gym – Receptacle cover plate missing, two light switches not working
4. Restrooms
 - a. Girls Restroom by Science Lab 4 – Loose toilet seat, graffiti on ceiling, door sticks
 - b. Girls and Boys Restroom by RSP3 – Loose toilet seats
 - c. Boys Locker Room – Loose toilet seat, hand dryer not working, missing light covers
 - d. Girls Portable Restroom – Ceiling tiles missing or damaged, lights out
 - e. Boys Portable Restroom – Ceiling tiles missing or damaged, broken toilet seat, light switch cover plate missing
5. Windows/Doors/Gates/Fences
 - a. Gym – Door closers broken
6. Overall Rating: GOOD