

Williams Visit Report

School: Portola Middle School

Visit Date: September 13, 2010

Facility Notes:

1. Fire Safety
 - a. Room 8 – Table blocking fire exit window, no exit sign
 - b. Room 17 – Cabinet blocking exit window
 - c. Room 20 – Cabinet blocking exit window
 - d. Room 25 – Table blocking fire exit window
 - e. Room 31 – Table blocking fire exit window
 - f. Room 33 – Fire exit blocked

2. Windows/Doors/Gates/ Fences
 - a. Room 33 – Fire exit blocked

3. Overall Rating: GOOD
 - a. Note: Principal has advised all teachers to move furniture that is blocking egress by windows.